



Integrated Engineers, Inc. conducted a treatability test that showed the Floccin 1105 worked well at a dosage of 3.0 grams/1,000 ml of wastewater (treatment dosage of 25 lbs. of Floccin-1105 to 1,000 gallons of wastewater). The treated pH was 7.0. The floc formed and clarity of the treated water was good.